


Falz-klemme Part No. 365 229

material: NIRO



DEHN + SÖHNE



non-binding figure

application: overground

conductor connected	test result
1st conductor : Rd 8 NIRO 2nd conductor : FI 30x0,7 NIRO	N
1st conductor : Rd 8 Al 2nd conductor : FI 30x0,7 Al	N
1st conductor : Rd 8 St/tZn 2nd conductor : FI 30x0,7 St/tZn	N
1st conductor : Rd 8 Al 2nd conductor : FI 40x3 Al	H
1st conductor : Rd 8 NIRO 2nd conductor : FI 30x2 NIRO	H
1st conductor : Rd 8 St/tZn 2nd conductor : FI 30x2 St/tZn	H
1st conductor : Rd 8 Cu 2nd conductor : FI 30x0,7 Cu	H

caption

withstand lightning current class H 100 kA (10/350 µs)
withstand lightning current class N 50 kA (10/350 µs)
Detailed data of testing conditions can be requested on demand.